

From: [Brian Moore](#)
To: [Abshire, David](#); [Zehner, Warren](#)
Cc: [Bob Piniewski](#)
Subject: Malone Service Company Superfund Site ER Update
Date: Wednesday, July 08, 2015 2:50:05 PM

Dear Warren and David,

As discussed yesterday, ENTACT will be providing additional labor to operate WDW-138 24 hours a day as long as the formation will continue to accept water within the permitted limits. The additional workers are being mobilized to the site from out of state and should be arriving by arriving this Friday and Saturday. Today ENTACT's current crew started injection at 6:30 and will operate the well until 6:30 this evening to increase the well operation time until the additional labor arrives.

The Malone Cooperating Parties (MCP) subcontractor, Boatman Industries, who is in charge of bringing WDW-73 online, will be on-site tomorrow to install a metal shade cover over the injection pump skid. They will also pressure test the piping and make any repairs needed to the system. Boatman has confirmed that both of their subcontractors will be on-site Monday (7/13/15) to move forward with the remaining start up controls wiring and data logging equipment installation to allow the startup/shutdown of the system. It is estimated that this work will take 2 days. Once the wiring and data logging work is complete, we will then move forward with the initial start up to confirm there are no issues with the data logging and start up components, as well as no leaks in any of the piping or tanks. Once any troubleshooting during the startup/shutdown is complete, we will be able to move forward with constant injection and observe our injection flow rate, injection pressure and annulus pressure.

Should you have any questions you can contact me by email or on my cellphone. Thanks and we appreciate your assistance during this Emergency Response.

Kindest Regards,

Brian Moore
RD/RA Construction Manager
Malone Service Superfund Site

Project Navigator, Ltd.
10497 Town & Country Way, Suite 830
Houston, TX 77024
Direct: 713.468.5961
Cell: 713.534.4546
Fax: 713.468.4515



9716123